

**2016 Annual Drinking Water Quality Report  
(Testing Performed January through December 2015)**

**LINCOLN WATER WORKS**  
33 Municipal Complex Drive  
Lincoln, AL 35096

Phone 205-763-7777  
Fax 205-763-7394

We are pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

<b>Number of Customers</b>	Approximately 3300 service connections	
<b>Water Sources</b>	Three (3) groundwater wells producing from the Knox Group aquifer	
	Purchased water from Oxford Water Works	
<b>Additional Connections</b>	Emergency connection with the City of Talladega Water and Sewer	
<b>Water Treatment</b>	Chlorination	
<b>Storage Capacity</b>	Six (6) storage tanks with a total capacity of 4,300,000 gallons	
<b>Council Members</b>	Claude (Bud) Kitchin, Mayor	Billy Pearson, Council
	Shelly Barnhart, Council	Chris Watson, Council
	Sadie Britt, Council	Jean Burke, Council

**Source Water Assessment**

In compliance with the Alabama Department of Environmental Management (ADEM), **Lincoln Water Works** has developed a Source Water Assessment plan that will assist in protecting our water sources. This plan provides additional information such as potential sources of contamination. It includes a susceptibility analysis, which classifies potential contaminants as high, moderate, or non-susceptible to contaminating the water source. The assessment has been performed, public notification has been completed, and the plan has been approved by ADEM. A copy of the report is available in our office for review during normal business hours, or you may purchase a copy upon request for a nominal reproduction fee.

Please help us make this effort worthwhile by protecting our source water. Carefully follow instructions on pesticides and herbicides you use for your lawn and garden, and properly dispose of household chemicals, paints and waste oil.

**Monitoring Schedule**

**Lincoln Water Works** routinely monitors for constituents in your drinking water according to Federal and State laws. This report shows the results of the *most recent* monitoring, according to regulations governing drinking water.

<b>Constituent Monitored</b>	<b>Lincoln</b>	<b>Oxford</b>
Inorganic Contaminants	2013	2015
Lead/Copper	2014	2013
Microbiological Contaminants	current	current
Nitrates	2015	2015
Radioactive Contaminants	2010	2014
Synthetic Organic Contaminants (including pesticides and herbicides)	2013	2015
Volatile Organic Contaminants	2015	2015
Disinfection By-products	2015	2015

## General Information

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. MCL's, defined in a List of Definitions in this report, are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and it can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, storm water run-off, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water.

Some people may be more vulnerable to contaminants in drinking water than the general population. People who are immunocompromised such as cancer patients undergoing chemotherapy, organ transplant recipients, HIV/AIDS positive or other immune system disorders, some elderly, and infants can be particularly at risk from infections. People at risk should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Based on a study conducted by ADEM with the approval of the EPA a statewide waiver for the monitoring of asbestos and dioxin was issued. Thus, monitoring for these contaminants was not required.

## Information about Lead

Lead in drinking water is rarely found in source water but is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Use *only* water from the cold-water tap for drinking, cooking, and *especially for making baby formula*. Hot water is more likely to cause leaching of lead from plumbing materials. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. These recommended actions are very important to the health of your family.

Lead levels in your drinking water are likely to be higher if:

- Your home or water system has lead pipes, or
- Your home has faucets or fittings made of brass which contains some lead, or
- Your home has copper pipes with lead solder and you have naturally soft water, and
- Water often sits in the pipes for several hours.

If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

## Questions?

If you have any questions about this report or concerning your water utility, please contact **Danny Groce** at City Hall. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled City Council meetings. They are held on the **2<sup>nd</sup> and 4<sup>th</sup> Tuesday of each month at City Hall at 5:00 p.m.**

More information about contaminants to drinking water and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (1-800-426-4791).

## Detected Contaminants

We have learned through our monitoring and testing that some constituents have been detected. We are pleased to report that our drinking water meets or exceeds federal and state requirements.

TABLE OF DETECTED DRINKING WATER CONTAMINANTS								
Contaminants	Violation	Lincoln	Oxford	Unit	MCLG	MCL	Likely Source of Contamination	
	Y/N	Detected	Detected	Msmt				
Chlorine	NO	--	1.00-1.53	ppm	MRDLG=4	MRDL=4	Water additive used to control microbes	
Turbidity	NO	--	0.016-0.026 100%<0.5	NTU	n/a	TT	Soil runoff	
Alpha emitters	NO	0.8 ± 1.0	2.5 ± 0.9	PCi/l	0	15	Erosion of natural deposits	
Copper	NO	0.071 * 0 > AL	0.134 0>AL	PCi/l	0	15	Erosion of natural deposits	
Nitrate (as Nitrogen)	NO	0.55-1.18	0.30-1.02	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	
Trichloroethylene	NO	ND	ND-2.92	ppb	0	5	Discharge from metal degreasing sites and other factories	
TTHM [Total trihalomethanes]	NO	ND	WTP 10.8-26.4	Distribution ND	ppb	0	80	By-product of drinking water chlorination
HAA5 [Total haloacetic acids]	NO	ND	WTP 7.21-17.6	Distribution ND	ppb	0	60	By-product of drinking water chlorination
<b>Unregulated Contaminants</b>								
Chloroform	NO	ND	ND-12.0	ppb	n/a	n/a	Naturally occurring in the environment or as a result of discharge or agricultural runoff	
Bromodichloromethane	NO	ND	ND-5.09	ppb	n/a	n/a	Naturally occurring in the environment or as a result of discharge or agricultural runoff	
Chlorodibromomethane	NO	ND	ND-2.01	ppb	n/a	n/a	Naturally occurring in the environment or as a result of discharge or agricultural runoff	
<b>Secondary Contaminants</b>								
Chloride	NO	1.80-5.22	6.48	ppm	n/a	250	Naturally occurring in the environment or as a result of discharge or agricultural runoff	
Hardness	NO	6.79-181	142	ppm	n/a		Naturally occurring in the environment or as a result of treatment with water additives	
Iron	NO	ND-0.79	ND	ppm	n/a	0.30	Naturally occurring in the environment; erosion of natural deposits; leaching from pipes	
pH	NO	7.13-7.45	8.15	S.U.	n/a	n/a	Naturally occurring in the environment or as a result of treatment with water additives	
Sodium	NO	0.86-204	4.51	ppm	n/a	n/a	Naturally occurring in the environment	
Sulfate	NO	0.98-2.77	2.69	ppm	n/a	250	Naturally occurring in the environment or as a result of discharge or agricultural runoff	
Total Dissolved Solids	NO	160-212	144	ppm	n/a	500	Naturally occurring in the environment or as a result of discharge or agricultural runoff	

\* Figure shown is 90<sup>th</sup> percentile and # of sites above Action Level = 0

### DEFINITIONS

Action Level- the concentration of a contaminant that, if exceeded, triggers treatment or other requirements which a water system must follow.

Coliform Absent (ca)- Laboratory analysis indicates that the contaminant is not present.

Disinfection byproducts (DBPs)- are formed when disinfectants used in water treatment plants react with bromide and/or natural organic matter (i.e., decaying vegetation) present in the source water. Different disinfectants produce different types or amounts of disinfection byproducts. Disinfection byproducts for which regulations have been established include trihalomethanes (TTHM), haloacetic acids (HAA5), bromate, and chlorite.

Initial Distribution System Evaluation (IDSE)-a one-time study conducted by water systems to identify distribution system locations with high concentrations of trihalomethanes (THMs) and haloacetic acids (HAAs).

Locational Running Annual Average (LRAA)-yearly average of all the DPB results at each specific sampling site in the distribution system. The highest distribution site LRAA is reported in the Table of Detected Contaminants.

Maximum Contaminant Level-(mandatory language) The Maximum Allowed (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal-(mandatory language) The Goal (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL)-the highest level of a disinfectant allowed in drinking water

Millirems per year (mrem/yr)-measure of radiation absorbed by the body.

Nephelometric Turbidity Unit (NTU)-a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Non-Detects (ND)- laboratory analysis indicates that the constituent is not present above detection limits of lab equipment.

Not Reported (NR)-laboratory analysis, usually Secondary Contaminants, not reported by water system. EPA recommends secondary standards to water systems but does not require systems to comply.

Parts per billion (ppb) or Micrograms per liter (µg/l)-one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per million (ppm) or Milligrams per liter (mg/l)-one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/l)-one part per quadrillion corresponds to one minute in 2,000,000,000 years, or a single penny in \$10,000,000,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l)-one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Picocuries per liter (pCi/L)-picocuries per liter is a measure of the radioactivity in water.

RAA-Running annual average

Standard Units (S.U.)-pH of water measures the water's balances of acids and bases and is affected by temperature and carbon dioxide gas. Water with less than 6.5 could be acidic, soft, and corrosive. A pH greater than 8.5 could indicate that the water is hard.

Treatment Technique (TT)- a required process intended to reduce the level of a contaminant in drinking water.

Variations & Exemptions (V&E)-State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

At the end of this report a list of *Primary Drinking Water Contaminants* and a list of *Unregulated Contaminants* for which our water system routinely monitors. These contaminants were *not* detected in your drinking water unless they are listed in the *Table of Detected Drinking Water Contaminants*.

STANDARD LIST OF PRIMARY DRINKING WATER CONTAMINANTS					
Contaminant	MCL	Unit of Msmt	Contaminant	MCL	Unit of Msmt
<b>Bacteriological Contaminants</b>			o-Dichlorobenzene	600	ppb
Total Coliform Bacteria	<5%	present or absent	p-Dichlorobenzene	75	ppb
Fecal Coliform and E. coli	0	present or absent	1,2-Dichloroethane	5	ppb
Turbidity	TT	NTU	Nitrite	1	ppm
<b>Radiological Contaminants</b>			Total Nitrate and Nitrite	10	ppm
Beta/positron emitters	4	mrem/yr	Selenium	50	ppb
Alpha emitters	15	pCi/l	Thallium	2	ppb
Combined radium	5	pCi/l	<b>Organic Contaminants</b>		
Uranium	30	pCi/l	2,4-D	70	ppb
<b>Inorganic Chemicals</b>			2,4,5-TP(Silvex)	50	ppb
Antimony	6	ppb	Acrylamide	TT	ppm
Arsenic	10	ppb	Alachlor	2	ppb
Asbestos	7	MFL	Benzo(a)pyrene [PAHs]	200	ppt
Barium	2	ppm	Carbofuran	40	ppb
Beryllium	4	ppb	Chlordane	2	ppb
Cadmium	5	ppb	Dalapon	200	ppb
Chromium	100	ppb	Di (2-ethylhexyl)adipate	400	ppb
Copper	AL=1.3	ppm	Di (2-ethylhexyl)phthalate	6	ppb
Cyanide	200	ppb	Dinoseb	7	ppb
Fluoride	4	ppm	Diquat	20	ppb
Lead	AL=15	ppb	Dioxin [2,3,7,8-TCDD]	30	Picograms/l
Mercury	2	ppb	Chloramines	4	ppm
Nitrate	10	ppm	Chlorite	1	ppm
Endothall	100	ppb	Total haloacetic acids	60	ppb
Endrin	2	ppb	1,1-Dichloroethylene	7	ppb
Epichlorohydrin	TT	ppm	cis-1,2-Dichloroethylene	70	ppb
Glyphosate	700	ppb	trans-1,2-Dichloroethylene	100	ppb
Heptachlor	400	Nanograms/l	Dichloromethane	5	ppb
Heptachlor epoxide	200	Nanograms/l	1,2-Dichloropropane	5	ppb
Hexachlorobenzene	1	ppb	Ethylbenzene	700	ppb
Hexachlorocyclopentadiene	50	ppb	Ethylene dibromide	50	ppt
Lindane	200	Nanograms/l	Styrene	100	ppb
Methoxychlor	40	ppb	Tetrachloroethylene	5	ppb
Oxamyl [Vydate]	200	ppb	1,1,1-Trichloroethane	200	ppb
Oxamyl [Vydate]	200	PCBs	1,1,2-Trichloroethane	5	ppb
Pentachlorophenol	1	ppb	Trichloroethylene	5	ppb
Picloram	500	ppb	Total trihalomethanes	80	ppb
Simazine	4	ppb	Toluene	1	ppm
Toxaphene	3	ppb	Vinyl Chloride	2	ppb
Benzene	5	ppb	Xylenes	10	ppm
Carbon tetrachloride	5	ppb	Chlorine	4	ppm
Chlorobenzene	100	ppb	Chlorine Dioxide	800	ppb
Dibromochloropropane	200	ppt	Bromate	10	ppb
<b>UNREGULATED CONTAMINANTS</b>					
1,1 – Dichloropropene	Aldicarb	Chloroform	Metolachlor		
1,1,1,2-Tetrachloroethane	Aldicarb Sulfone	Chloromethane	Metribuzin		
1,1,2,2-Tetrachloroethane	Aldicarb Sulfoxide	Dibromochloromethane	N - Butylbenzene		
1,1-Dichloroethane	Aldrin	Dibromomethane	Naphthalene		
1,2,3 - Trichlorobenzene	Bromobenzene	Dicamba	N-Propylbenzene		
1,2,3 - Trichloropropane	Bromochloromethane	Dichlorodifluoromethane	O-Chlorotoluene		
1,2,4 - Trimethylbenzene	Bromodichloromethane	Dieldrin	P-Chlorotoluene		
1,3 – Dichloropropane	Bromoform	Hexachlorobutadiene	P-Isopropyltoluene		
1,3 – Dichloropropene	Bromomethane	Isopropylbenzene	Propachlor		
1,3,5 - Trimethylbenzene	Butachlor	M-Dichlorobenzene	Sec - Butylbenzene		
2,2 – Dichloropropane	Carbaryl	Methomyl	Tert - Butylbenzene		
3-Hydroxycarbofuran	Chloroethane	MTBE	Trichlorofluoromethane		